

ELECTRONICS CORPORATION OF INDIA LIMITED  
ENGINEERING SERVICES DIVISION

EC:ESD:Corrigendum:563:2015


4<sup>th</sup> September, 2015


**CORRIGENDUM NO.-1 TO NIT NO.563/2015**

- I. The tender document of work at **Sl.no.15** i.e Supply, Installation, testing and commissioning of 250KVA, 415 Volt, 50Hz, 3 Phase DG set with AMF panel and LT power distribution panel for NPR facility, ECIL, Hyderabad, the changes in Section -I, VII and VIII may read as

S/N	Existing specification	Specification to be Read as
<b>4.</b> <b>Section-I</b> , Instructions to Tenderers  <u>Pre-qualification cum technical evaluation criteria.</u> (Page no.5)	Copy of Electrical License issued by State Electrical Inspectorate	Copy of Electrical License issued by any State Electrical Licensing authority
<b>1.</b> <b>Section - VII</b> , <u>Price bid</u> (Page no.64)	For item no.1, in the specification, exhaust piping, thermal logging, asbestos rope insulation, cladding etc.,	Exhaust piping, thermal insulation by using glass wool, cladding etc.
<b>Section-VIII</b> <u>Technical Specifications</u> (Page no.69)	<b>General Technical specifications</b> <b>Acoustic Enclosure:</b>  Exhaust piping with Thermal logging, Asbestos rope insulation and cladding	<b>General Technical specifications-</b> <b>Acoustic Enclosure:</b>  Exhaust piping, thermal insulation by using glass wool, cladding etc.
<b>Section-VIII</b> <u>Technical Specifications</u> (Page no.70)	<b>General Technical specifications-Commissioning</b>  Note: It is the responsibility of contractor to arrange the necessary load, fuel, lube oil, tools and test equipment required to carry out the tests at the site without any additional cost.	<b>General Technical specifications-Commissioning</b>  Note: Load test to be carried out on DG set at Manufacturers place.

All other terms and conditions of the tender notice shall remain unchanged.

  
(A.Rahiman)  
SM(Civil)  
Tenders & Purchase

  
(K.Sridhar Rao)  
In-charge / ESD